

WATER QUALITY M E M O R A N D U M

Utah Coal Regulatory Program

October 10, 2003

TO: Internal File

THRU: Daron Haddock, Permit Supervisor

FROM: Steve Fluke, Reclamation Hydrogeologist

RE: 2001, Second Quarter Water Monitoring, Canyon Fuel Company,
SUFCO Mine, C/041/0002

1. Was data submitted for all of the MRP required sites? YES [X] NO []

2. On what date does the MRP require a five-year resampling of baseline water data.

The MRP does not require a five-year resampling of baseline water data.

Resampling due date.

Not specified.

3. Were all required parameters reported for each site? YES [X] NO []

4. Were irregularities found in the data? YES [] NO [X]

5. Were DMR forms submitted for all required sites?

1 st quarter, 1 st month,	YES [X]	NO []
2 nd month,	YES [X]	NO []
3 rd month,	YES [X]	NO []
2 nd quarter, 1 st month,	YES [X]	NO []
2 nd month,	YES [X]	NO []
3 rd month,	YES [X]	NO []

All required UPDES sites were monitored.

6. Were all required DMR parameters reported? YES [X] NO []

7. Were irregularities found in the DMR data? YES [X] NO []

1st quarter, 3rd month: UPDES site 002 - total iron reported at 1.17 mg/l exceeds requirement of 1.0 mg/l.

8. Based on your review, what further actions, if any, do you recommend?

None, all requirements met. The 2nd quarter total iron reported for UPDES site 002 did not exceed requirements.